


Availability and reliability – CLP Power Hong Kong Limited

Availability and reliability



1. The numbers are derived by calculating the average of data from the most recent three years. For example, the figures under year 2025 are the 3-year averages of data from 2023 to 2025.
2. 2023-2025 average for CLP Power was 1.8 minutes; Taking out the impact due to Major Event Day (such as Typhoon Saola in 2023, Typhoons Wipha & Ragasa in 2025), the three-year average was 1.1 minutes.